



## UTICA CITY SCHOOL DISTRICT

320 Elizabeth Street  
Utica, NY 13501

Michael M. Ferraro  
Maintenance Foreman  
mferraro@uticaschools.org

Ph. (315) 792-2214  
Fax. (315) 792-2260

April 7, 2017

Dear Parents & Guardians: Kernan Elementary School

On September 6, 2016, Governor Cuomo signed new legislation requiring the testing of drinking water in New York public schools for lead levels. The new legislation is explained in a document entitled: "State Department of Health Issues New Regulations to Mandate Lead Testing in New York Elementary Schools by October 30th, and in the Secondary Schools by October 31<sup>st</sup>; New York is the First State in the Nation to Complete Lead Testing in All School Districts by the End of 2016." To access this document, please visit the following link:

<https://www.governor.ny.gov/news/governor-cuomo-signs-landmark-legislation-test-drinking-water-new-york-schools-lead>

The regulations adopted by the N.Y.S. Department of Health require that a public school take samples from all water outlets in each of its buildings to ascertain whether any lead readings in the water exceed the state required "action-levels." A "water outlet" is defined as a potable water fixture currently or potentially used for drinking or cooking purposes, including, but not limited to, bubblers, drinking fountains, and faucets.

In anticipation of this legislation, we have tested all applicable water fixtures to test for lead levels. A full Comprehensive Report of the sampling program is available on the school's website: <http://www.uticaschools.org/kernan>.

As noted in our letter to you of November 14, 2016, there were 79 water fixtures tested; and \*13 showed lead levels above the allowable .015 ppb (parts per billion) marks. We have already addressed the outlets which tested in excess of state requirements by temporarily shutting off the drinking fixtures impacted and posting signage that alerts students and staff to avoid drinking the water from these outlets. It should be noted that under the State's regulations, the water from these outlets could still be used for handwashing and cleaning purposes.

In February 2017, we conducted a second sampling of water from these fixtures. [\*Please note that certain types of outlets were not required to be retested.] For those fixtures retested and requiring it, we installed permanent signs reading: "Do Not Drink." Please see below:

Location:	Rm. 101 P.E. Office – Bathroom Sink .0322 ppb
Location:	Rm. 138 – Bathroom Sink .015 ppb
Location:	Rm. 232 – Classroom Sink .0175 ppb
Location:	Rm. 024a Closet – Bathroom Sink .0376 ppb
Location:	Rm. 020 Closet – Custodial Sink .0407 ppb

continued....

April 7, 2017

Again, if you should have any questions on the above at any time, please feel free to contact me on my office phone: (315) 792-2231.

Thank you,



Michael M. Ferraro  
Maintenance Foreman

cc: Bruce Karam – Superintendent of Schools  
Lori Eccleston – Dir., Curriculum & Instruction, K-12  
Mary Kay Van Dreason – Dir., Food Service  
Alicia Mroz – Admin. for Pre-K/Student Programs  
Building Principal  
FILE: Lead-In-Water 2016/17