

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
ALBR 1	5/14/2021 10:30	5/29/2021 13:30	70174221001	Lead	<1.0	15	ug/L
ALBR 2	5/14/2021 10:31	5/29/2021 13:31	70174221002	Lead	<1.0	15	ug/L
ALBR 3	5/14/2021 10:31	5/29/2021 13:32	70174221003	Lead	<1.0	15	ug/L
ALBR 4	5/14/2021 10:32	5/29/2021 13:35	70174221004	Lead	3.1	15	ug/L
ALBR 5	5/14/2021 10:32	5/29/2021 13:39	70174221005	Lead	1.7	15	ug/L
ALBR 6	5/14/2021 10:32	5/29/2021 13:40	70174221006	Lead	3.4	15	ug/L
ALBR 7	5/14/2021 10:33	5/29/2021 13:41	70174221007	Lead	90.6	15	ug/L
ALBR 8	5/14/2021 10:37	5/29/2021 13:42	70174221008	Lead	8.9	15	ug/L
ALBR 9	5/14/2021 10:40	5/29/2021 13:43	70174221009	Lead	25.0	15	ug/L
ALBR 10	5/14/2021 10:41	5/29/2021 13:44	70174221010	Lead	9.9	15	ug/L
ALBR 11	5/14/2021 10:42	5/29/2021 13:45	70174221011	Lead	23.6	15	ug/L
ALBR 12	5/14/2021 10:43	5/29/2021 13:46	70174221012	Lead	5.1	15	ug/L

NYSDOH Action Level for Lead of 15 ppb